

From :

Commissioner  
Municipal Corporation  
Faridabad.

To:

**M/s Swatantra Land & Finance Pvt. Ltd.**  
**"Indraprastha Apartment - II"**  
Sector -30,  
Faridabad

Memo No.: 235 / FSD .


Dated: 4.09.2014.

Sub.: Approval of Fire Fighting scheme from Fire Safety Point of Group housing Scheme " Indraprastha Apartment-II" Measuring 1.09 Acres in Sector -30, Faridabad Developed by M/s. Swatantra Land & Finance Pvt. Ltd.

Reference to your letter SLFPL/CMC/2014/454 Dated 02.06.2014,

The case for the approval for the first Fighting Scheme has been examined by Fire Officer, Sector-15A & Fire Officer Ballabgarh Faridabad. The Fire Fighting scheme has been found as per the National Building Code of India Part - IV, 1983 revised 2005 so the proposed fire fighting scheme is approved from the Fire Safety point of view only with the following conditions :-

1. The proposed Fire Fighting Scheme is approved in the building plan submitted, subject to the approval of Building Plan as per rules applicable.
2. The overhead water tank for fire fighting shall be constructed in such a ways that domestic water tank shall be filled up from the overflow of fire water tank.
3. As soon as the installation of the Fire fighting arrangements are completed the same shall be got inspected/ tested and clearance should be obtained from this department.



Fire Officer  
For Commissioner  
Municipal Corporation Faridabad